

ADDENDUM NO. ME-01

Attention: Scott Bailey

Address: Shoalts & Zaback Architects Ltd.
206-4 Cataraqui St.
Kingston, ON K7K 1Z7

Date: April 21, 2026

Project #: CE-6074

Project: HFI Pyrotechnics New Lab Building

Cc. ---

Please amend the drawings and specifications for the above noted project as described below. Identify this addendum on the tender form to insure a complete tender form.

1. MECHANICAL

1.1. Drawing M7, : **Add** Note 12 as follows

12. 100Ø (4") INSULATED EXHAUST TERMINATED WITH SCHEDULED METAL WALL CAP.
INCLUDE FLEXIBLE RUBBER HIGH TEMP COUPLING AT EQUIPMENT.

2. ELECTRICAL

2.1. Drawing E2: Provide 3 **additional** ZB fixture along access road to the west.

2.2. Drawing E3: **Revise** fixture type AA, AB and AF to **remove** built in occupancy requirement.
Add remote occupancy sensors where required as shown.

2.3. Drawing E3: **Revise** fixture type CA and quantity.

3. ATTACHMENTS

3.1. Electrical Drawings: E2 and E3- Issued for Addendum No. ME-01.

END OF ADDENDUM No. ME-01

WE MAKE BUILDINGS WORK

LONDON
9-1385 NORTH ROUTLEDGE PARK
LONDON, ON N6H 5N5

T 519 472 7640

E info@callidus.ca

KINGSTON
4 CATARAQUI STREET., SUITE 100
KINGSTON, ON. K7K 1Z7

T 613 900 0845

W www.callidus.ca

KITCHENER
210-137 GLASGOW STREET
KITCHENER, ON. N2G 4X8

T 519 340-1885