

ADDENDUM NO. 2

PROJECT: 1338 PRINCESS STREET, KINGSTON, ON
KINGSTON CO-OPERATIVE HOMES 2022 INTERIOR
RENOVATIONS

PROJECT NO.: RJC # TOR.125103.0002

ISSUED DATE: JUNE 07, 2022

ISSUED BY: GARRETT PERKINS

1.0 REFERENCE TO SECTION 06 40 00 – FINISHES KITCHEN & BATH

- .1 The following is to modify item 2.2.1.1 Exposed Materials: Comply with the Following:
 - .1 Thermofoil – Faced 3/4" Medium Density Fiberboard (MDF) complying with ANSI A208.2, Grade M-2 with a solid colour vinyl film adhesively bonded to Fibreboard.
Acceptable Products:
- .2 The following is to modify item 2.3 Countertop Materials
 - .1 Plastic Laminate: High-pressure decorative laminate complying with NEMA LD
 - .1 Grade: HGS 10 (or higher)
 - .2 Provide through-color plastic laminate
 - .3 Grade for Backer Sheet: BKL
 - .2 Particleboard: ANSI A208.1, Grade M-2
 - .3 Plywood: Exterior softwood plywood complying with PS 1, Grade C-C plugged, touch sanded.
 - .4 Configuration: Provide Countertops with the following front, backsplash, and end-splash style:
 - .1 Front: Futura (Double Radius) Edge - 3/8" Radius
 - .2 Backsplash: Futura (Double Radius) Edge - 3/8" Radius
 - .3 End Splash: None



.5 Colour: To imitate granite/stone. Owner to select colour/finish during submittal stage.

.6 Acceptable Manufacturer:

.1 Wilsonart

.2 Formica

.3 Premoule

.4 Or Approved Alternative

2.0 QUESTIONS

.1 Tile Tub Surround:

- a. Are we to use a Wedi or Schluter board? Or directly adhere to a mildew resistant drywall?

Contractor can use Wedi or Schluter Board as an approved alternative to the cement board.

This Addendum shall be read in conjunction with and becomes part and parcel of the tender documents, and shall supersede drawings and/or specifications where applicable.

END OF ADDENDUM NO. 2