

The following additions, deletions, and amendments are hereby made part of the drawings and specifications and shall be accounted for in the Bid Price.

DRAWINGS:

Clarification:

The exterior wall siding for both the garage addition and the administrative building shall be Commercial Rib by Ideal Roofing. Colours:

- .1 Garage Addition: to match existing.
- .2 Administrative Building: To be selected by the Consultant.

SPECIFICATIONS:

Section 06 20 00 - Finish Carpentry

Delete 2.3.1.1 in its entirety and substitute the following:

- 2.3.1.1 Base: Thermoplastic rubber wall base. Standard of acceptance: Johnsonite Dura-Cove wall base by Tarkett.
 - .1 Thickness: 3.17 mm.
 - .2 Height: 101.6 mm.
 - .3 Profile: Coved.
 - .4 Premoulded inside and outside corners.
 - .5 Colour to be selected by the Consultant.
 - .6 Install in accordance with the manufacturer's recommendations.

Section 07 46 23 - Prefinished Wood Siding

Delete Section 07 46 23 in its entirety.

Section 09 30 13 - Ceramic Tiling

Add new Section 09 30 13.

Section 10 21 13 - Phenolic Toilet Compartments

Add new Section 10 21 13.

Section 10 28 10 - Washroom Accessories

Add new paragraph 2.4.8:

- .8 Hand dryer: Standard of acceptance: Frost Airline Series Code 1181. Provide one hand dryer in each washroom.

Section 12 24 13 - Roller Window Shades

Add new Section 12 24 13.

END OF DOCUMENT