
To: **Bell + Associates**
Amey Taylor, Sr. Technologist/Architectural Designer
Client: Bell + Associates
Location: 186 Pembroke St. E., Pembroke, ON K8A 3J7

Date: 2026-07-14

Reference: 420-2301-03 – 240 County Road 4 Millhaven ON – Administration Building

This Addendum forms part of the contract documents and is to be read, interpreted, and coordinated with all other parts. The cost of all contained herein is to be included in the contract sum. The following revisions supersede the information contained in the original drawings and specifications issued for the above-named project to the extent referenced and shall become part thereof. Acknowledge receipt of this Addendum by inserting its number and date on the Tender Form. Failure to do so may subject the Bidder to disqualification.

Electrical

Clarifications/Modifications/Additions:

1. Refer to updated drawing for correct scaling on drawing E4 (site plan).

END OF ADDENDUM