



Date Issued: July 16, 2026

To: All Proponents – Public Notice

Title: Millhaven Admin Building Construction and Operations Building Renovation.

Reference #. RFP 2026-24 – Addendum #3

From: Mario Cruz, Corporate Procurement Specialist

Note:

Loyalist Township has deemed it necessary to provide additional information relating to the above referenced RFP

This addendum forms an integral part of the above referenced RFP. Such addenda may contain important information, including significant changes to the above referenced RFP. The respondent is deemed to have read and taken into account all addenda issued by the Township and posted on the Loyalist Township Procurement Site

Questions and Responses:

1. pressure system location and specs?

Existing pressure system is located in the Renovated Operations Building and is to be maintained.

2. well line size?

Unknown but no change is required.

3. On drawing M-2 of the administration building, can you please confirm the size of the underground domestic water piping shown? Can you also confirm the proposed piping material?

Underground domestic water to be 1 1/4" Municipex.

4. Is the mechanical contractor only to bring the underground domestic water piping a few feet outside the building? As shown on drawing M-2 of the administration building. Or are we to bring the underground domestic water piping to the existing well?

Mechanical contractor to bring 1 1/4" Municipex. water service from Operations Building into Admin Building mechanical room and provide scope as described in mechanical contract drawings.

5. Can you please provide a water entry detail for the new administration building? There are no valves, fittings, or accessories shown on the mechanical drawings for water entry.

1 1/4" Municipex. water service from Operations Building into Admin Building mechanical room

6. Vodaland Canada is seeking approval as an alternative to the trench drain. We propose the 4 inch PRO 100P Load class D pre-sloped Polypropylene polymer drain c/w Galvanized steel reinforcement edge rails, ductile iron grates, and inline catch basin. Load class D.

This substitution is acceptable

Deadlines:

Closing date is July 20 2026 – 11:00 AM Local Time.

**ALL INQUIRIES CONCERNING THIS PROCUREMENT SHALL BE DIRECTED TO
THE LOYALIST TOWNSHIP PROCUREMENT SITE**

END OF ADDENDUM #3